

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.**

No. Spl / Samp Paldi / 001

Date : 21.02.2022

It is certified that an Inspection team headed by _____
DINESH CHOUDHARY, ASSISTANT ENGINEER (Name of Officers
with designation) from PHEO Bhilwara (Name of
Department/Office) Inspected the VIDYA GLOBAL SCHOOL, PALDI, BHILWARA
& WATER TESTING REPORT NO. 648 at 21.02.2022 (Name & Address of
the School) on 21.02.2022 and found that the VIDYA GLOBAL SCHOOL, VILLAGE
PALDI, P.S. SUWANA, TEH & DIST. BHILWARA (Name of school) has safe
drinking water facilities for the students and members of staff of the Institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of THREE YEARS.

Signature with Seal : [Signature]
Name : सहायक अभियन्ता
जन स्वास्थ्य अभियांत्रिक विभाग
Designation : ग्रामीण उपखण्ड, भीलवाड़ा

To

VIDYA GLOBAL SCHOOL
Village - PALDI, P.S. SUWANA
TEH & DIST. BHILWARA
(Name & Address of the Institution)



Public Health Engineering Department
Office of Junior Chemist
District Lab, Bhilwara



No. Lab / Tech (Bact.)/2021-22/

648

Dated

21/2/22

To,

Dr Ashok Kumar Choudhary
(Principal) Vidya Global School
Paladi Bhilwara

Bhilwara

Report of Bacteriological Examination of Water

Reference: - Your Letter No. 518

Dated 17.02.22

Date of Receipt 17-Feb

Sample Taker

Sandip Sargara

| Lab Sample No. | Date Time | Date of Exam. | Village / Town / City | Source & Location | Residual Chlorine (mg/L) | Total Coli-forms (MPN / 100 ml) | E Coli (MPN / 100 mL) | Remark |
|----------------|--------------------|---------------|-----------------------|-------------------------------|--------------------------|---------------------------------|-----------------------|--------|
| 2634 | 17/Feb 11.00 AM | 17-Feb | Palri (B) | RO Vidya Global School Paladi | Nil | Nil | Nil | Sat. |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |

Satisfactory

Unsat: - Unsatisfactory

Junior Chemist

PHED Dist. Lab BHILWARA

Dated

No. Lab / Tech (Bact.)/2021-22/

- Copy to 1. The Chief Chemist, Public Health Engineering Department, Rajasthan, Jaipur
2. Senior Chemist, PHED Regional Laboratory, Ajmer

Junior Chemist
PHED Dist. Lab BHILWARA



Public Health Engineering Department

OFFICE OF JUNIOR CHEMIST

District Laboratory, Bhilwara

No. Lab/Tech(Chem)/2021-22/

640

Dated : 21/2/22

REPORT OF THE CHEMICAL EXAMINATION OF WATER

Dr Ashok Kumar Choudhary
(Principal) Vidya Global School
Paladi Bhilwara

District: Bhilwara
Block: Bhilwara

Reference : Vidya Global School Paldi Bhilwara Letter No. 598


Dated: 14/02/22

Date of Receipt : 17/02/22

Exam. Date: Feb-22

| LS No. | BIS 10500; 2012 Drinking Water Standards | | DL-Bhl / Rt/ 20-21/ 1472 | | | | |
|--|--|------------------------------|-----------------------------|------|--|--|--|
| Panchyat | | | Paladi | | | | |
| Village | | | Palri (B) | | | | |
| Habitation | | | Paladi | | | | |
| Source | Maximum Desirable Limit | Maximum Permissible Limit | RO Vidya Global School | | | | |
| Date of Collection | | | 17/02/22 | | | | |
| Name of Sample Taker | | | Sandip sargara PTI | | | | |
| <i>Note : - All results except pH are in mg/L.</i> | | | | | | | |
| 1 | pH | 6.5-8.5 | NR | 8.81 | | | |
| 2 | TDS | 500 | 2000 | 114 | | | |
| 3 | Total Alkalinity (As CaCO ₃) | 200 | 600 | 60 | | | |
| 4 | Total Hardness (As CaCO ₃) | 200 | 600 | 52 | | | |
| 5 | Turbidity | 1 | 5 | 0 | | | |
| 6 | Chloride | 250 | 1000 | 20 | | | |
| 7 | Nitrate | 45 | NR | 1.12 | | | |
| 8 | Sulphate | 200 | 400 | 16 | | | |
| 9 | Fluoride | 1 | 1.5 | 0.06 | | | |
| 10 | Residual Chlorine | 0.2 | 1 | Nil | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |

Samples Not Collected by Laboratory.
Not for Legal Purposes


Junior Chemist
PHED District Laboratory,
Bhilwara